



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 324

Customer

Facility Name: Verland Foundation
Address: 212 Iris Rd.
Sewickley, PA 15143

Sample Collection

Date: 10/5/26
Time: 11:52 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 10/8/26
Time: 10:00 AM
Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/6/26	9:55 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/6/26	9:55 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/5/26	6:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	10/5/26	11:52 AM	AMH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/5/26	11:52 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/5/26	11:52 AM	AMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor