



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 327

Customer

Facility Name: Washington & Jefferson

Address: 60 S. Lincoln St.
Washington, PA 15301

Matrix: Recreational Water

Source Type: Lap Pool

Sample Collection

Date: 10/7/26

Time: 10:34 AM

Method: Grab

Sample Final Analysis

Date: 10/9/26

Time: 5:00 PM

Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/7/26	4:45 PM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/7/26	4:45 PM	MH	SM 9222B
Standard plate count:	5700/ml	200/ml	10/7/26	4:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	10/7/26	10:34 AM	EG	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/7/26	10:34 AM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/7/26	10:34 AM	EG	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor