



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-1

Lab# 342

Customer

Facility Name: Woodland Hills High School

Address: 2550 Greensburg Pike
Pittsburgh, PA 15221

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 10/6/26

Time: 9:35 AM

Method: Grab

Sample Final Analysis

Date: 10/9/26

Time: 9:00 AM

Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/7/26	8:55 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/7/26	8:55 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/6/26	3:48 PM	MH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	10/6/26	9:35 AM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/6/26	9:35 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/6/26	9:35 AM	SH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)