



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-2**

**Lab# 348**

**Customer**

**Facility Name:** Wyndham Grand

**Address:** 600 Commonwealth Place  
Pittsburgh, PA 15222

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 10/5/26

**Time:** 1:40 PM

**Method:** Grab

**Sample Final Analysis**

**Date:** 10/8/26

**Time:** 10:00 AM

**Analyst:** JC

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method   |
|---------------------|---------|-----------------|----------------------|---------|----------|
| Escherichia Coli:   | Absent  | Absent          | 10/6/26 9:55 AM      | MH      | SM 9222G |

|                  |          |          |                 |    |          |
|------------------|----------|----------|-----------------|----|----------|
| Total coliforms: | 0/100mls | 2/100mls | 10/6/26 9:55 AM | MH | SM 9222B |
|------------------|----------|----------|-----------------|----|----------|

|                       |      |        |                 |    |          |
|-----------------------|------|--------|-----------------|----|----------|
| Standard plate count: | 0/ml | 200/ml | 10/5/26 6:10 PM | SL | SM 9215B |
|-----------------------|------|--------|-----------------|----|----------|

| Additional Analysis | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
|---------------------|----------|-----------------|----------------------|---------|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls        | 10/6/26 10:50 AM     | JC      | SM 9230C |

| Field Analysis | Results  | Reporting limit | Date/Time       | Analyst | Method |
|----------------|----------|-----------------|-----------------|---------|--------|
| pH:            | 7.5 SU   | 7.2 - 7.8 SU    | 10/5/26 1:40 PM | SL      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 10/5/26 1:40 PM | SL      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 10/5/26 1:40 PM | SL      | Visual |

**Sample comments**

*Andre Smith*

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)