



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-1**

**Lab# 518**

**Customer**

**Facility Name:** YMCA - Beaver  
  
**Address:** 2236 3rd Ave  
New Brighton, PA 15066

**Sample Collection**

**Date:** 9/22/26  
**Time:** 3:03 PM  
**Method:** Grab

**Matrix:** Recreational Water  
  
**Source Type:** Spa

**Sample Final Analysis**

**Date:** 9/25/26  
**Time:** 10:00 AM  
**Analyst:** JC

| <b>Accredited Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| Escherichia Coli:          | Absent         | Absent                 | 9/23/26                     | 9:30 AM  | AH             | SM 9222G      |
| Total coliforms:           | 0/100mls       | 2/100mls               | 9/23/26                     | 9:30 AM  | AH             | SM 9222B      |
| Standard plate count:      | 0/ml           | 200/ml                 | 9/22/26                     | 5:20 PM  | SL             | SM 9215B      |
| <b>Additional Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
| Fecal Streptococcus        | 0/100mls       | 2/100mls               | 9/23/26                     | 10:00 AM | JC             | SM 9230C      |
| <b>Field Analysis</b>      | <b>Results</b> | <b>Reporting limit</b> | <b>Date/Time</b>            |          | <b>Analyst</b> | <b>Method</b> |
| pH:                        | 7.1 SU         | 7.2 - 7.8 SU           | 9/22/26                     | 3:03 PM  | SL             | DPD           |
| Chlorine:                  | 1.0 mg/l       | 1.0 - 5.0 mg/l         | 9/22/26                     | 3:03 PM  | SL             | DPD           |
| Turbidity:                 | 1 NTU          | 1 - 2 NTU              | 9/22/26                     | 3:03 PM  | SL             | Visual        |

**Sample comments**

Andre Smith, Lead Supervisor