



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-1**

**Lab# 518**

**Customer**

**Facility Name:** YMCA - Beaver  
  
**Address:** 2236 3rd Ave  
New Brighton, PA 15066

**Sample Collection**

**Date:** 10/5/26  
**Time:** 3:14 PM  
**Method:** Grab

**Matrix:** Recreational Water  
  
**Source Type:** Spa

**Sample Final Analysis**

**Date:** 10/8/26  
**Time:** 10:00 AM  
**Analyst:** JC

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method   |
|---------------------|---------|-----------------|----------------------|---------|----------|
| Escherichia Coli:   | Absent  | Absent          | 10/6/26 9:55 AM      | JC      | SM 9222G |

|                       |          |          |                 |    |          |
|-----------------------|----------|----------|-----------------|----|----------|
| Total coliforms:      | 0/100mls | 2/100mls | 10/6/26 9:55 AM | JC | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml   | 10/5/26 6:10 PM | SL | SM 9215B |

| Additional Analysis | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
|---------------------|----------|-----------------|----------------------|---------|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls        | 10/6/26 10:50 AM     | JC      | SM 9230C |

| Field Analysis | Results   | Reporting limit | Date/Time       | Analyst | Method |
|----------------|-----------|-----------------|-----------------|---------|--------|
| pH:            | 8.0 SU    | 7.2 - 7.8 SU    | 10/5/26 3:14 PM | AMH     | DPD    |
| Chlorine:      | 10.0 mg/l | 1.0 - 5.0 mg/l  | 10/5/26 3:14 PM | AMH     | DPD    |
| Turbidity:     | 1 NTU     | 1 - 2 NTU       | 10/5/26 3:14 PM | AMH     | Visual |

**Sample comments**

Andre Smith, Lead Supervisor