



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 155

Customer

Facility Name: *Holiday Inn*
Address: *20 S 10th St.*
Pittsburgh, PA 15203

Sample Collection

Date: *10/5/26*
Time: *2:33 PM*
Method: *Grab*

Sample Final Analysis

Date: *10/8/26*
Time: *10:00 AM*
Analyst: *JC*

Matrix: *Recreational Water*
Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/6/26	9:55 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/6/26	9:55 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	10/5/26	6:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	10/5/26	2:33 PM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/5/26	2:33 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/5/26	2:33 PM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)