



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 270

Customer

Facility Name: Science and Technology Academy
Address: 107 Thackeray St.
Pittsburgh, PA 15213

Matrix: Recreational Water
Source Type: Pool Shallow

Sample Collection

Date: 10/5/26
Time: 12:25 PM
Method: Grab

Sample Final Analysis

Date: 10/8/26
Time: 10:00 AM
Analyst: JC

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	10/6/26	9:30 AM	MH	SM 9222G
Total coliforms:	0/100mls	A	10/6/26	9:30 AM	MH	SM 9222B
Standard plate count:	0/ml	A	10/5/26	4:05 PM	MH	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.2 SU	C	10/5/26	12:25 PM	JT	DPD
Chlorine:	2.0 mg/l	B	10/5/26	12:25 PM	JT	DPD
Turbidity:	1 NTU	A	10/5/26	12:25 PM	JT	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)