



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 045

Customer

Facility Name: Carrick High School
Address: 125 Parkfield St.
Pittsburgh, PA 15210

Matrix: Recreational Water
Source Type: Pool Deep

Sample Collection

Date: 10/5/26
Time: 10:10 AM
Method: Grab

Sample Final Analysis

Date: 10/8/26
Time: 10:00 AM
Analyst: JC

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	10/6/26	9:30 AM	MH	SM 9222G
Total coliforms:	0/100mls	A	10/6/26	9:30 AM	MH	SM 9222B
Standard plate count:	0/ml	A	10/5/26	4:05 PM	MH	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	10/5/26	10:10 AM	JT	DPD
Chlorine:	3.0 mg/l	A	10/5/26	10:10 AM	JT	DPD
Turbidity:	1 NTU	A	10/5/26	10:10 AM	JT	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)