# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

**Lab ID No. 02-04041**

**W-10**

***Lab# 2779***

| ***Customer*** | | ***Sample Collection*** | |
|---|---|---|---|
| *Facility Name:* | *Bridgewater Crossing* | *Date:* | *8/25/25* |
| | | *Time:* | 1:39 PM |
| *Address:* | *206 Mulberry St Ext.*<br>*Beaver, PA 15009* | *Method:* | *Grab* |
| | | ***Sample Final Analysis*** | |
| *Matrix:* | *Recreational Water* | *Date:* | *8/28/25* |
| | | *Time:* | *9:00 AM* |
| *Source Type:* | *Pool* | *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 8/26/25 | 10:15 AM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/26/25 | 10:15 AM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/25/25 | 5:20 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 8/25/25 | 1:39 PM | AMH | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 8/25/25 | 1:39 PM | AMH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/25/25 | 1:39 PM | AMH | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor