Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 047

[redacted]

Customer

Facility Name: *Chartiers Valley High School*

Address: *50 Thoms Run Rd.*
Bridgeville, PA 15017

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *4/21/26*
Time: 2:40 PM
Method: *Grab*

Sample Final Analysis

Date: *4/24/26*
Time: *11:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	4/22/26	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	4/22/26	10:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	4/21/26	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	4/21/26	2:40 PM	SL	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	4/21/26	2:40 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	4/21/26	2:40 PM	SL	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)