Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 101

Customer		**Sample Collection**	
Facility Name:	*Fairfield Inn & Suites -North*	*Date:*	*4/21/26*
		Time:	9:00 AM
Address:	*901 Providence Blvd.* *Pittsburgh, PA 15237*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*4/24/26*
		Time:	*10:00 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	4/22/26	9:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	4/22/26	9:30 AM	JC	SM 9222B
Standard plate count:	20/ml	200/ml	4/21/26	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	4/21/26	9:00 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	4/21/26	9:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	4/21/26	9:00 AM	VH	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)