Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2799

[redacted]

Customer		***Sample Collection***	
Facility Name:	*Midland Boro*	*Date:*	*8/4/25*
		Time:	3:25 PM
Address:	*936 Midland Ave.* *Midland, PA 15059*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*8/7/25*
		Time:	*11:20 AM*
Source Type:	*Large Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	1:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	1:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	7:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/4/25	3:25 PM	AH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	8/4/25	3:25 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	3:25 PM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2799

[redacted]

Customer		***Sample Collection***	
Facility Name:	*Midland Boro*	*Date:*	*8/4/25*
		Time:	3:25 PM
Address:	*936 Midland Ave.* *Midland, PA 15059*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*8/7/25*
		Time:	*11:20 AM*
Source Type:	*Large Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	1:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	1:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	7:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/4/25	3:25 PM	AH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	8/4/25	3:25 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	3:25 PM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor