Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 267

Customer

Facility Name: *Ringold High School*

Address: *1 Ram Drive*
Monongahela, PA 15063

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *4/20/26*
Time: 2:15 PM
Method: *Grab*

Sample Final Analysis

Date: *4/23/26*
Time: *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	4/21/26	9:55 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	4/21/26	9:55 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	4/20/26	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	4/20/26	2:15 PM	SH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	4/20/26	2:15 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	4/20/26	2:15 PM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor