Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-15

Lab# 2802

[redacted]

Customer		***Sample Collection***	
Facility Name:	*Rolling Hills Aqua Park*	*Date:*	*8/26/25*
		Time:	10:53 AM
Address:	*110 WarriorsWay*	*Method:*	*Grab*
	McMurray, PA 15317		
		Sample Final Analysis	
Matrix:	*Rolling Hills Aqua Park*	*Date:*	*8/29/25*
		Time:	*10:30 AM*
Source Type:	*Spray Pad*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/25	12:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/25	12:00 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/26/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/26/25	10:53 AM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/26/25	10:53 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/25	10:53 AM	AF	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor