# Dreams Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

**Lab ID No. 02-04041**

**PPS**

***Lab# 003***

| ***Customer*** | | ***Sample Collection*** | |
|---|---|---|---|
| *Facility Name:* | *Allderdice H.S.* | *Date:* | *4/21/26* |
| | | *Time:* | 12:23 PM |
| *Address:* | *2409 Shady Ave.* | *Method:* | *Grab* |
| | *Pittsburgh, PA 15217* | | |
| | | ***Sample Final Analysis*** | |
| *Matrix:* | *Recreational Water* | *Date:* | *4/24/26* |
| | | *Time:* | *11:00 AM* |
| *Source Type:* | *Pool Deep* | *Analyst:* | *AS* |

| Accredited Analysis | Results | Rating | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | A | 4/22/26 | 10:30 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | A | 4/22/26 | 10:30 AM | JC | SM 9222B |
| Standard plate count: | 0/ml | A | 4/21/26 | 5:00 PM | AS | SM 9215B |

| Field Analysis | Results | Rating | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.6 SU | A | 4/21/26 | 12:23 PM | MM | DPD |
| Chlorine: | 3.0 mg/l | A | 4/21/26 | 12:23 PM | MM | DPD |
| Turbidity: | 1 NTU | A | 4/21/26 | 12:23 PM | MM | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor