



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 2075

Customer

Facility Name: *Camp Guyasuta*
Address: *300 23rd Street*
Sharpsburg, PA 15215

Sample Collection

Date: *7/20/26*
Time: *12:10 PM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *7/23/26*
Time: *9:30 AM*
Analyst: *AS*

Source Type: *Splash Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/21/26	9:20 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/21/26	9:20 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	7/20/26	2:34 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/20/26	12:10 PM	LL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/20/26	12:10 PM	LL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/20/26	12:10 PM	LL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor