



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-11

Lab# 2077

Customer

Facility Name: Camp Sky Meadow
Address: 164 Sky Meadow Lane
Avonmore, PA 15618

Sample Collection

Date: 7/22/26
Time: 1:15 PM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 7/25/26
Time: 12:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/26	11:40 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/26	11:40 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/26	6:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/22/26	1:15 PM	DW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/22/26	1:15 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/26	1:15 PM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor