



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 448

Customer

Facility Name: *Fox Chapel High School*

Address: *611 Field Club Rd*
Pittsburgh, PA 15238

Matrix: *Recreational Water*

Source Type: *Shallow End*

Sample Collection

Date: *7/20/26*

Time: *10:40 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/23/26*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/21/26	9:20 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/21/26	9:20 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	7/20/26	2:34 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/20/26	10:40 AM	LL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/20/26	10:40 AM	LL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/20/26	10:40 AM	LL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor