



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

Lab# 2289

Customer

Facility Name: Ingomar Swim Club
Address: 1512 Ingomar Heights Rd.
Pittsburgh, PA 15237

Sample Collection

Date: 7/27/26
Time: 10:30 AM
Method: Grab

Sample Final Analysis

Date: 7/30/26
Time: 9:00 AM
Analyst: AS

Matrix: Recreational Water
Source Type: Shallow End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/28/26	8:45 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/28/26	8:45 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	7/27/26	4:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/27/26	10:30 AM	IS	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/27/26	10:30 AM	IS	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/27/26	10:30 AM	IS	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)