



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 386

Customer

Facility Name: *Residence Inn Cranberry*
Address: *1308 Freedom Rd.*
Cranberry, PA 16066

Sample Collection

Date: *7/28/26*
Time: *12:05 PM*
Method: *Grab*

Sample Final Analysis

Date: *7/31/26*
Time: *10:00 AM*
Analyst: *AS*

Matrix: *Recreational Water*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/26	9:50 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/26	9:50 AM	MD	SM 9222B
Standard plate count:	100/ml	200/ml	7/28/26	5:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/28/26	12:05 PM	EG	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/28/26	12:05 PM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/26	12:05 PM	EG	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)