



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-11

Lab# 2791

Customer

Facility Name: Saltsburg Pool
Address: 230 10th St.
Saltsburg, PA 15681

Sample Collection

Date: 7/28/26
Time: 12:30 PM
Method: Grab

Matrix: Recreational Water
Source Type: Spray Pad

Sample Final Analysis

Date: 7/31/26
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/26	8:15 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/26	8:15 AM	SL	SM 9222B
Standard plate count:	5700/ml	200/ml	7/28/26	5:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/28/26	12:30 PM	SH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/28/26	12:30 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/26	12:30 PM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor