



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 449

Customer

Facility Name: Super 8 Hotel

Address: 2001 Leesburg Grove City Rd.
Mercer, PA 16137

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/29/26

Time: 9:15 AM

Method: Grab

Sample Final Analysis

Date: 8/1/26

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/26	8:30 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/26	8:30 AM	MD	SM 9222B
Standard plate count:	570/ml	200/ml	7/29/26	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/29/26	9:15 AM	MM	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	7/29/26	9:15 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/26	9:15 AM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)