



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-14

Lab# 2666

Customer

Facility Name: Danbury Farms
Address: 100 Carriage Dr
Freedom, PA 15042

Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 7/28/26
Time: 1:25 PM
Method: Grab

Sample Final Analysis

Date: 7/31/26
Time: 10:00 AM
Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/26 9:50 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/26 9:50 AM	MD	SM 9222B
Standard plate count:	570/ml	200/ml	7/28/26 5:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/28/26 1:25 PM	EG	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/28/26 1:25 PM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/26 1:25 PM	EG	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor