



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
W-1

Lab# 008

Customer

Facility Name: *Allegheny Valley School Ingram*

Address: *315 W. Prospect Ave.*
Pittsburgh, PA 15205

Sample Collection

Date: *9/28/26*
Time: *7:29 AM*
Method: *Grab*

Sample Final Analysis

Date: *10/1/26*
Time: *10:00 AM*
Analyst: *JC*

Matrix: *Recreational Water*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/29/26	9:55 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/29/26	9:55 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/28/26	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/28/26	7:29 AM	AMH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/28/26	7:29 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/28/26	7:29 AM	AMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor