



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 041

Customer

Facility Name: Carnegie Mellon
Address: 5000 Forbes Ave.
Pittsburgh, PA 15213

Matrix: Recreational Water

Source Type: Dive pool Shallow

Sample Collection

Date: 9/29/26
Time: 9:15 AM
Method: Grab

Sample Final Analysis

Date: 10/2/26
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/30/26	8:55 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/30/26	8:55 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/29/26	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/29/26	9:15 AM	JT	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/29/26	9:15 AM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/29/26	9:15 AM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Andre Smith, Lead Supervisor