



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 163

Customer

Facility Name: Holiday Inn Express

Address: 3695 State Route 31
Donegal, PA 15628

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 9/28/26

Time: 10:00 AM

Method: Grab

Sample Final Analysis

Date: 10/1/26

Time: 9:30 AM

Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/29/26	9:25 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/29/26	9:25 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/28/26	4:06 PM	MH	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	9/29/26	10:30 AM	JC	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	9/28/26	10:00 AM	JC	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/28/26	10:00 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/28/26	10:00 AM	JC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)