



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 234

Customer

Facility Name: North Allegheny High School

Address: 10375 Perry Hwy.
Wexford, PA 15090

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 9/30/26

Time: 9:30 AM

Method: Grab

Sample Final Analysis

Date: 10/3/26

Time: 9:30 AM

Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/1/26	9:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/1/26	9:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/30/26	3:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/30/26	9:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/30/26	9:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/30/26	9:30 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor