



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 262

Customer

Facility Name: *Rehabilitation Institute*

Address: *1405 Shady Ave.
Pittsburgh, PA 15217*

Matrix: *Recreational Water*

Source Type: *Pool - Sm*

Sample Collection

Date: *9/29/26*

Time: *1:00 PM*

Method: *Grab*

Sample Final Analysis

Date: *10/2/26*

Time: *9:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/30/26 8:55 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/30/26 8:55 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/29/26 4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/29/26 1:00 PM	JT	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/29/26 1:00 PM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/29/26 1:00 PM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Andre Smith, Lead Supervisor