



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Extra

Lab# 2749

Customer

Facility Name: Executive House

Address: 800 Beau Dr.
WJChington, PA 15301

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 9/28/26

Time: 10:30 AM

Method: Grab

Sample Final Analysis

Date: 1/0/00

Time: 9:30 AM

Analyst: JC

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/29/26	9:25 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/29/26	9:25 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/28/26	4:06 PM	MH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/28/26	10:30 AM	JC	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/28/26	10:30 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/28/26	10:30 AM	JC	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)