



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Extra

Lab# 2758

Customer

Facility Name: *Seven Springs Resort*

Address: *777 Waterwheel Dr.
Champion, PA 15622*

Matrix: *Recreational Water*

Source Type: *Outdoor Spl/JCh Pad*

Sample Collection

Date: *9/28/26*

Time: *10:30 AM*

Seven Springs Method: *Grab*

Sample Final Analysis

Date: *10/1/26*

Time: *9:30 AM*

Analyst: *JC*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/29/26	9:25 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/29/26	9:25 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/28/26	4:06 PM	MH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	9/28/26	10:30 AM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/28/26	10:30 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/28/26	10:30 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor