



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**

Lab ID No. 02-04041

**N-2**

**Lab# 278**

**Laboratory Analysis Report**

**Customer**

**Facility Name:** Shaler Area Elementary School  
**Address:** 700 Scott Ave.  
Glenshaw, PA 15116

**Sample Collection**

**Date:** 9/30/26  
**Time:** 1:30 PM  
**Method:** Grab

**Matrix:** Recreational Water

**Sample Final Analysis**

**Date:** 10/3/26  
**Time:** 10:30 AM  
**Analyst:** JC

**Source Type:** Pool Shallow

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 10/1/26              | 10:00 AM | MH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 10/1/26              | 10:00 AM | MH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 9/30/26              | 4:45 PM  | MH      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.4 SU   | 7.2 - 7.8 SU    | 9/30/26   | 1:30 PM | VH      | DPD    |
| Chlorine:      | 1.0 mg/l | 1.0 - 5.0 mg/l  | 9/30/26   | 1:30 PM | VH      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 9/30/26   | 1:30 PM | VH      | Visual |

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor