



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 328

Customer

Facility Name: *Washington & Jefferson*

Address: *60 S. Lincoln St.
Washington, PA 15301*

Matrix: *Recreational Water*

Source Type: *Dive Pool*

Sample Collection

Date: *9/30/26*

Time: *12:00 PM*

Method: *Grab*

Sample Final Analysis

Date: *10/3/26*

Time: *10:30 AM*

Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/1/26	10:00 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/1/26	10:00 AM	MH	SM 9222B
Standard plate count:	5700/ml	200/ml	9/30/26	4:45 PM	MH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	9/30/26	12:00 PM	EG	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/30/26	12:00 PM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/30/26	12:00 PM	EG	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)