# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

**Lab ID No. 02-04041**

**C-1**

***Lab# 044***

| ***Customer*** | | ***Sample Collection*** | |
|---|---|---|---|
| *Facility Name:* | *Carnegie Mellon* | *Date:* | *4/14/26* |
| | | *Time:* | 11:30 AM |
| *Address:* | *5000 Forbes Ave.*<br>*Pittsburgh, PA 15213* | *Method:* | *Grab* |
| | | ***Sample Final Analysis*** | |
| *Matrix:* | *Recreational Water* | *Date:* | *4/17/26* |
| | | *Time:* | *10:30 AM* |
| *Source Type:* | *Spa* | *Analyst:* | *AS* |

| **Accredited Analysis** | **Results** | **Reporting limit** | **Incubation Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 4/15/26 | 10:00 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 4/15/26 | 10:00 AM | JC | SM 9222B |
| Standard plate count: | 5/ml | 200/ml | 4/14/26 | 5:02 PM | SL | SM 9215B |

| **Additional Analysis** | **Results** | **Reporting limit** | **Incubation Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| Fecal Streptococcus | 0/100mls | 2/100mls | 4/15/26 | 11:00 AM | JC | SM 9230C |

| **Field Analysis** | **Results** | **Reporting limit** | **Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 4/14/26 | 11:30 AM | DNP | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 4/14/26 | 11:30 AM | DNP | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 4/14/26 | 11:30 AM | DNP | Visual |

**Sample comments**

Andre Smith

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor