Lab ID No. 02-04041

# Dreams Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665

**PPS**

***Lab# 212***

## Laboratory Analysis Report

| ***Customer*** | | ***Sample Collection*** | |
|---|---|---|---|
| *Facility Name:* | *Langley High School* | *Date:* | *4/15/26* |
| | | *Time:* | 8:50 AM |
| *Address:* | *2940 Sheradan Blvd.* | *Method:* | *Grab* |
| | *Pittsburgh, PA 15204* | | |
| | | ***Sample Final Analysis*** | |
| *Matrix:* | *Recreational Water* | *Date:* | *4/18/26* |
| | | *Time:* | *10:30 AM* |
| *Source Type:* | *Pool Deep* | *Analyst:* | *AS* |

| Accredited Analysis | Results | Rating | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | A | 4/16/26 | 10:00 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | A | 4/16/26 | 10:00 AM | JC | SM 9222B |
| Standard plate count: | 0/ml | A | 4/15/26 | 5:15 PM | SL | SM 9215B |

| Field Analysis | Results | Rating | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.6 SU | A | 4/15/26 | 8:50 AM | MM | DPD |
| Chlorine: | 1.0 mg/l | D | 4/15/26 | 8:50 AM | MM | DPD |
| Turbidity: | 1 NTU | A | 4/15/26 | 8:50 AM | MM | Visual |

**Sample comments**

Andre Smith

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)