Lab ID No. 02-04041

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Service

Lab# 425

Customer

Facility Name: *Chatham University*

Address: *1 Woodland Rd.*
Pittsburgh, PA 15232

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *2/24/26*
Time: 9:40 AM
Method: *Grab*

Sample Final Analysis

Date: *2/26/26*
Time: *10:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/25/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/25/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	2/24/26	3:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	2/24/26	9:40 AM	MB	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	2/24/26	9:40 AM	MB	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/24/26	9:40 AM	MB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor