Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 177

Customer		***Sample Collection***	
Facility Name:	*Hyatt Place*	*Date:*	*2/23/26*
		Time:	9:16 AM
Address:	*2112 Racetrack*	*Method:*	*Grab*
	Washington,PA 15301		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*2/25/26*
		Time:	*10:30 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	2/24/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/24/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	2/23/26	4:10 PM	SL	SM 9215B

Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	7.3 SU	7.2 - 7.8 SU	2/23/26	9:16 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	2/23/26	9:16 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/23/26	9:16 AM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor