Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 274

Customer		***Sample Collection***	
Facility Name:	*Seven Springs Resort*	*Date:*	*2/23/26*
		Time:	10:55 AM
Address:	*777 Waterwheel Dr.*	*Method:*	*Grab*
	Champion, PA 15622		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*2/25/26*
		Time:	*10:30 AM*
Source Type:	*Spa-Wagner*	*Analyst:*	*AS*

Accredited Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	2/24/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/24/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/23/26	4:10 PM	SL	SM 9215B

Additional Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Fecal Streptococcus	0/100mls	2/100mls	2/24/26	10:30 AM	SL	SM 9230C

Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	8.0 SU	7.2 - 7.8 SU	2/23/26	10:55 AM	JC	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	2/23/26	10:55 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/23/26	10:55 AM	JC	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)