Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 278

Customer		***Sample Collection***	
Facility Name:	*Shaler Area Middle School*	*Date:*	*2/25/26*
		Time:	1:30 PM
Address:	*705 Scott Ave.* *Glenshaw, PA 15116*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*2/26/26*
		Time:	*3:30 PM*
Source Type:	*Pool Shallow*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/25/26	3:05 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/25/26	3:05 PM	SL	SM 9222B
Standard plate count:	70/ml	200/ml	2/25/26	2:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	2/25/26	1:30 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	2/25/26	1:30 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/25/26	1:30 PM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor