# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

**Lab ID No. 02-04041**

**N - 1**

***Lab# 353***

**Customer**

*Facility Name:* *YMCA - Butler*

*Address:* *339 North Washington St.*
*Butler, PA 16001*

*Matrix:* *Recreational Water*

*Source Type:* *Pool*

**Sample Collection**

*Date:* *2/23/26*
*Time:* 3:10 PM
*Method:* *Grab*

**Sample Final Analysis**

*Date:* *2/25/26*
*Time:* *10:30 AM*
*Analyst:* *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 2/24/26 | 10:00 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 2/24/26 | 10:00 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 2/23/26 | 5:19 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 2/23/26 | 3:10 PM | BH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 2/23/26 | 3:10 PM | BH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 2/23/26 | 3:10 PM | BH | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor