Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab# 376 **Lab ID No. 02-04041**

Laboratory Analysis Report

	Drury Hotel	***Sample Collection***	
		Date:	*11/2/26*
		Time:	11:20 AM
Address:	*745 Grant St.*	*Method:*	*Grab*
	Pittsburgh, PA 15219		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*11/5/26*
		Time:	*9:00 AM*
Source Type:	*Pool*	*Analyst:*	*JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/3/26	8:55 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/3/26	8:55 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	11/2/26	5:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	11/2/26	11:20 AM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	11/2/26	11:20 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/2/26	11:20 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor