Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 448

Customer

Facility Name: *Fox Chapel High School*

Address: *611 Field Club Rd*
Pittsburgh, PA 15238

Matrix: *Recreational Water*

Source Type: *Shallow End*

Sample Collection

Date: *11/4/26*
Time: 9:40 AM
Method: *Grab*

Sample Final Analysis

Date: *11/6/26*
Time: *4:30 PM*
Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/4/26	4:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/4/26	4:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	11/4/26	4:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	11/4/26	9:40 AM	MH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	11/4/26	9:40 AM	MH	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/4/26	9:40 AM	MH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor