Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-3

Lab# 472

Customer		***Sample Collection***	
Facility Name:	*Hollidaysburg HS*	*Date:*	*11/3/26*
		Time:	1:00 PM
Address:	*1510 North Montgomery St. Hollidaysburg, PA 16648*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*11/6/26*
		Time:	*10:30 AM*
Source Type:	*Pool*	*Analyst:*	*JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/4/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/4/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	11/3/26	5:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	11/3/26	1:00 PM	DNP	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	11/3/26	1:00 PM	DNP	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/3/26	1:00 PM	DNP	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)