Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 223

Customer

Facility Name: *McKeesport High School*

Address: *1960 Eden Park Blvd.*
Mckeesport, PA 15132

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *11/2/26*
Time: 2:00 PM
Method: *Grab*

Sample Final Analysis

Date: *11/5/26*
Time: *9:00 AM*
Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/3/26	8:55 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/3/26	8:55 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	11/2/26	4:00 PM	MH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	11/2/26	2:00 PM	JC	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	11/2/26	2:00 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/2/26	2:00 PM	JC	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)