**Dream Pools and Spas**
**1105 Washington Blvd**
**Pittsburgh, Pennsylvania 15206**
**(412) 661- 7665**

**Service**

# Laboratory Analysis Report

*Lab#* *313*

**Lab ID No. 02-04041**

***Customer***

*Facility Name:* *UPMC Sports Rehab - Cranberry*

*Address:* *8000 Cranberry Springs Drive*
*Cranberry Township, PA 16066*

*Matrix:* *Recreational Water*

*Source Type:* *Spa*

***Sample Collection***

*Date:* *11/3/26*
*Time:* 10:45 AM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *11/6/26*
*Time:* *10:30 AM*
*Analyst:* *JC*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 11/4/26 | 10:00 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 11/4/26 | 10:00 AM | JC | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 11/3/26 | 3:56 PM | MH | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Fecal Streptococcus | 0/100mls | 2/100mls | 11/4/26 | 10:00 AM | JC | SM 9230C |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 11/3/26 | 10:45 AM | JR | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 11/3/26 | 10:45 AM | JR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 11/3/26 | 10:45 AM | JR | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor