Lab ID No. 02-04041

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Service

Lab# ***340***

Laboratory Analysis Report

Customer

Facility Name: *Winchester Apts*

Address: *540 N. Neville St.*
Pittsburgh, PA 15213

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *11/2/26*
Time: 10:00 AM
Method: *Grab*

Sample Final Analysis

Date: *11/5/26*
Time: *9:00 AM*
Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/3/26	8:55 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/3/26	8:55 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	11/2/26	5:20 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	1/0/00	12:00 AM	0	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	11/2/26	10:00 AM	JR	DPD
Chlorine:	2.2 mg/l	1.0 - 5.0 mg/l	11/2/26	10:00 AM	JR	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/2/26	10:00 AM	JR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor