Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-1

Lab# 357

Customer		***Sample Collection***	
Facility Name:	*YMCA - East Suburban*	*Date:*	*11/3/26*
		Time:	12:40 PM
Address:	*2200 Golden Mile Hwy.*	*Method:*	*Grab*
	Plum, PA 15239		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*11/6/26*
		Time:	*9:30 AM*
Source Type:	*Shallow End*	*Analyst:*	*JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/4/26	9:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/4/26	9:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	11/3/26	2:40 PM	MH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	11/3/26	12:40 PM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	11/3/26	12:40 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/3/26	12:40 PM	SH	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)