

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

APM

Lab# *326*

Lab ID No. 02-04041

Customer

Facility Name: *Virginia Mansions*

Address: *2120 Greentree Rd.*
Pittsburgh, PA 15220

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *11/3/26*
Time: *7:22 AM*
Method: *Grab*

Sample Final Analysis

Date: *11/6/26*
Time: *9:30 AM*
Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/4/26	9:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/4/26	9:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	11/3/26	3:00 PM	MH	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	11/4/26	10:00 AM	JC	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	11/3/26	7:22 AM	MM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	11/3/26	7:22 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/3/26	7:22 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor