Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

PPS

Lab# 243

Laboratory Analysis Report

Customer

Facility Name: *Oliver H.S.*

Address: *2323 Brighton Rd.*
Pittsburgh, PA 15212

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *11/2/26*
Time: 1:40 PM
Method: *Grab*

Sample Final Analysis

Date: *11/5/26*
Time: *9:00 AM*
Analyst: *JC*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	11/3/26	8:55 AM	MH	SM 9222G
Total coliforms:	0/100mls	A	11/3/26	8:55 AM	MH	SM 9222B
Standard plate count:	0/ml	A	11/2/26	4:00 PM	MH	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	11/2/26	1:40 PM	JT	DPD
Chlorine:	2.0 mg/l	B	11/2/26	1:40 PM	JT	DPD
Turbidity:	1 NTU	A	11/2/26	1:40 PM	JT	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)