Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

PPS

Laboratory Analysis Report

Lab# ***270***

Customer		***Sample Collection***	
Facility Name:	*Science and Technology Academy*	*Date:*	*11/2/26*
		Time:	12:18 PM
Address:	*107 Thackeray St.*	*Method:*	*Grab*
	Pittsburgh, PA 15213		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*11/5/26*
		Time:	*9:00 AM*
Source Type:	*Pool Shallow*	*Analyst:*	*JC*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	11/3/26	8:55 AM	MH	SM 9222G
Total coliforms:	0/100mls	A	11/3/26	8:55 AM	MH	SM 9222B
Standard plate count:	0/ml	A	11/2/26	4:00 PM	MH	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	11/2/26	12:18 PM	JT	DPD
Chlorine:	2.0 mg/l	B	11/2/26	12:18 PM	JT	DPD
Turbidity:	1 NTU	A	11/2/26	12:18 PM	JT	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)